

APPENDIX - VIII

PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE.

No. 1460

Date : 29.05.25

It is certified that an inspection team headed by Executive Engineer (Name of Officers with designation) from P. H. E. D (Name of Department/Office) inspected the Bihar Vikas Vidyalaya, Karmaini Mohabbat Kuchaikote, Gopalganj (Bihar) on 26.05.2025 and found that the Bihar Vikas Vidyalaya has safe Drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/State/U.T Govt.

The above valid for a period of 01 year.

Tutor
26.05.25

Signature with Seal : Pardeep Kumar Jha

Name : Pardeep Kumar Jha

Designation : Executive Engineer

*Executive Engineer
P.H. Division, Gopalganj*

To

BIHAR VIKAS VIDYALAYA

KARMAINI MOHABBAT KUCHAIKOTE

GOPALGANJ BIHAR 841501

(Name & Address of the Institution)

Government of Bihar
Public Health Engineering Department
Water Quality Test Report

District Name: Gopalganj

Division Name: P.H.Division Gopalganj

SL No.	Block	Panchayat	Village	Ward No.	Location of Source	Parameters														Date of Testing	Remarks
						pH	Turbidity (NTU)	EC	TDS (mg/l)	Total Hardness (mg/l)	Calcium (mg/l)	Magnesium (mg/l)	Chloride (mg/l)	Total Alkalinity (mg/l)	Iron (mg/l)	Nitrate (mg/l)	Sulphate (mg/l)	Fluoride (mg/l)	Total Coli		
1	Kuchaykote	Sisawa	Karmaini Mohabat	7	Bihar vikas vidhyalaya	7.86	0.1	582	378	224	52	25	16	268	0.21	0.14	22.4	0.1	Absent	26/05/2025	
Desirable Limit*						6.5-8.5	1.0	-	500	200	75	30	250	200	0.3	45	200	1.0	-		
Permissible Limit* in absence of alternate source (IS 10500:2012 - 2nd revision & Rev 2015)						NR	5.0	-	2000	600	200	100	1000	600	1.0	NR	400	1.5	**		

26/05/2025

Lab Assistant / Chemist
 DLL, P.H. Division, Gopalganj

26/05/2025
 AE
 P.H.Division, Gopalganj

26/05/2025
 Executive Engineer
 P.H.Division, Gopalganj